



# City of Alvin

## Mobile Food Vendor and Special Event Fire Prevention Checklist

### Extinguisher Requirements

All cooking vendors and MFUs are required to have at least one extinguisher.

At least one class **ABC** extinguisher with a minimum of a 2A20BC rating. (5 pound)

- Visible current inspection ( date on tag or date of MFG less than one year)
- Fully Charged (gauge indicates full)
- Located within 30 feet of commercial type cooking equipment.




Does your cooking operation produce grease-laden vapors? (grills, fryers)

If so, in addition to the portable extinguisher listed above your operation requires;

**Class K** rated portable extinguisher.

- Visible Current inspection ( date on tag or date of MFG less than one year)
- Fully Charged (gauge indicates full)
- Located within 30 feet of commercial type cooking equipment.



**Fixed Suppression System-** cooking operations that produce grease-laden vapors require a commercial kitchen exhaust hood and duct system with an automatic fire extinguishing system, in addition to the portable extinguishers listed above. (Class I hood with fixed suppression system)

The suppression system shall have a visible current inspection (date on tag or date of MFG less than six months)

### Compressed Gas

LP/Propane cylinders are properly secured and remain secured by one of the following methods, unless actively being refilled;

- Nested and secured on the vehicle by one or more restraints.
- Secured by one or more restraints to a fixed object.
- Minimum of 10-foot clearance from any trash or combustible material.
- Not kept in passenger area of vehicle



### Egress and Emergency Access

The placement of the concession operation must not interfere with fire lane, fire break, fire hydrant, or exit access of any proximate structures.

### Tents

All tents shall be tied down and secure to the ground. Tents greater than 700 square feet require a separate permit from the fire marshal. Tents greater than 700 square feet shall be flame retardant and have a 2A20BC fire extinguisher.

### Generators

Generators shall be 10 feet from any tent or structure and have their own 2A20BC fire extinguisher.